



**DESIGN DATA & GENERAL NOTES**

- [1] Concrete strength  $f'_c = 4,000$  p.s.i. @ 28 days. Density = 150 pcf.
- [2] Cement - Portland Type I/II per ASTM C 150-92.
- [3] Admixtures & plasticizers per ASTM C 260-86 & C 494-92.
- [4] Reinforcing - A, B, C, D - 4x4, 6 Ga. wire mesh, ASTM C 185  
E, F - #3 rebars @ 5" centers, ASTM A 615

**COMPLIES WITH:**

- Baltimore City [BC-890.03]
- Baltimore County [W-15]
- Carroll County [W-9D]
- Harford County [W-17]
- Howard County [W 3.64]

**Mayer Brothers, Inc.**

6264 Race Road  
Elkridge, Maryland 21075  
Tel. 410.796.1434  
Fax. 410.796.1438  
www.mayerbrosprecast.com



**SECTIONAL VALVE VAULT - LARGE**  
Stock Item

Approx. Set Weight = 2,900 lbs.

Dwg. No. SVV-L

No Scale

August 2000